



October 11, 2019

**ADDENDUUM ACKNOWLEDGEMENT FORM
RFP 2019-2020-01 ADDENDUM #1**

Proposal No: RFP 2019-2020-01
Proposal Title: Indoor Batting Facility Electrical and Mechanical Buildout
Proposal Due Date: October 10, 2019 4:00 p.m. CST
Questions Due Date: October 14, 2019 4:00 p.m. CST
Revised Proposal Opening: October 30, 2019 2:00 p.m. CST

PLEASE BE ADVISED THAT THE FOLLOWING CHANGES ARE APPLICABLE TO THE ORIGINAL SPECIFICATIONS OF THE ABOVE-REFERENCED ITB:

This addendum includes the following:

RESPONSE TO WITTEN QUESTIONS RECEIVED OR ADDITIONAL BID DOCUMENTS:

1. Question: Is there going to be an electrical specification issued?

Response: No.

2. Question: Who is providing the lighting package? If the college is providing them can we get a submittal package?

Response: Provide the lighting package according to the fixture schedule.

3. Question: It says on page E300 that the rough-in for the power, lighting and fire alarm is complete. I don't think that is the case because there is no conduit installed overhead in the batting area. Only conduit that is installed that I saw was in the walls that is now covered by sheet except the bathrooms.

Response: Note is incorrect, only panel cans and conduit in enclosed walls are installed.

4. Question: If the contractor is providing the Fire Alarm system we need a set of specifications for what is required. And does the system need to be connected in some way to the existing campus system?

Response: College Contractor (Ivanco) will install system. Provide all conduit and boxes only required.

5. Question: Who is responsible for the tele/data work on page E500?

Response: College IT Department.

6. Question: Who is responsible for the telecom cabinet listed on page E300?

Response: College IT Department.

7. Question: Who is responsible for the ground bar for the telcom system and telephone backboard?

Response: College IT Department.

8. Question: There is a lift station shown, but per Ozzie that is not required?

Response: Not required.

9. Question: We need the information on the time clock that is shown on page E300 and a diagram of what it is controlling.

Response: Exterior lighting only.

10.Question: Is there a possibility that the bid date be move out to maybe the 30th?

Response: Yes, the new proposal opening date is now Wednesday, October 30th.

THIS ADDENDUM NOW BECOMES A PART OF THE ORIGINAL ITB.

THE ADDENDUM ACKNOWLEDGMENT FORM SHALL BE SIGNED BY AN AUTHORIZED COMPANY REPRESENTATIVE, DATED AND RETURNED WITH THE RESPONSE.

COMPANY NAME: _____

AUTHORIZED SIGNATURE: _____ DATE: _____